

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. LAB/UPJN/03

Dated: 12/08/2025

It is certified that an inspection team headed by Dr. Shamshad Ahmad (Technical Manager) from District Water Testing Laboratory Uttar Pradesh Jal Nigam Bahraich Inspected the BARROWS' BLUE BELLS SCHOOL on 12.08.2025 and on the basis of Water Test Report (Attached) bearing no. DWTL2025156 Dated 12.08.2025 of District Water Testing Laboratory Uttar Pradesh Jal Nigam Bahraich Certified that Barrows' Blue Bells School Gonda Road Block Chittora Village- Nagraur 271802 has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till **11.08.2026**

Signature with Seal .....
Name..... Dr. Shamshad Ahmad
Designation..... Technical Manager
Name & Address of the Office / Department:..... District Water Testing Laboratory Jal Nigam Bahraich

To,
Barrows' Blue Bells School
Gonda Road Block Chittora Village- Nagraur
Bahraich 271802

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


MANAGER
BARROWS' BLUE BELLS SCHOOL
BAHRAICH, U.P.


PRINCIPAL
BARROWS' BLUE BELLS SCHOOL
NAGRAUR, BAHRAICH U.P.



Analysis Report



District Level Water Analysis Laboratory , U.P Jal Nigam (Rural), BAHRAICH
Plot No. 2763, Jal Nigam Colony, Jail Road Bahraich, Uttar Pradesh-271801

Rept No.149	Chemical Test: DWTL2025156	Date of Rep	12.08.2025	S.No.	149	Page No.	1/1
ULR No.	TC132242500000198F						
Customer Details: BARROW'S BLUE BELL SCHOOL							
Office Name and Address of the Customer: Barrow's Blue Bell School Block Chittaura Nagraur Bahraich.							
Ref Letter No & Date							
Basic details of sample							
District	Bahraich	Block	Chittaura				
Gram Panchayat	Nagraur	Village	Nagraur				
Habitation		Location	Block Chittaura Nagraur Bahraich.				
Water Source	Tap Water	Sample No.	1				
Quantity of Sample	1000 ml	Date of Colled	11.08.2025				
Receiving Date	11.08.2025	Sample Collec					
Sample Depositer Name							
Analysis Start Date	11.08.2025	Analysis Completion Date	12.08.2025				
Environmental Condition							
Temperature		25±2°C		Relative Humidity		Upto 70%	
Technical Data of Analysis							
S.No.	Parameters	Units	Observed Value	Specified Values as		Ref. Method of Analysis	
				Acceptabl e Limit	Permissibl e Limit		
1	2	3	4	5	6	7	
1	pH	-	7.72	6.5-8.5	6.5-8.5	APHA 23 Edition 4500-H-B-2023 (Electrometric Method)	
2	Turbidity	(NTU)	0.66	1	5	IS 3025 (Part 10):2023 (Nephelometric Method)	
3	TDS	(mg/L)	344	500	2000	IS 3025 (Part 16):1984:2021 (Gravimetric Method)	
4	Chloride	(mg/L)	8.66	250	1000	IS 3025 (Part 32):2019 (Argentometric Method)	
5	Total Alkalinity	(mg/L)	221.33	200	600	IS 3025 (Part 23):2023 (Indicator Method)	
6	Total Hardness	(mg/L)	165.33	200	600	IS 3025 (Part 21):2019(EDTA Method)	
7	Sulphate	(mg/L)	3.26	200	400	IS 3025(Part 24):2022 (Turbiditic Method)	
8	Nitrate	(mg/L)	0.97	45	45	APHA 23 Edition 4500-NO ₃ -B-2017 (UV-Screening Metho	
9	Fluoride	(mg/L)	0.17	1	1.5	IS 3025(Part 60):2022 (Ion-Selective Electrode)	
10	Iron	(mg/L)	0.22	1	1	IS 3025(Part 53):2019 (Phenenthroanthraline Method)	
11	Arsenic	(mg/L)	0	0.01	0.01	IS 3025(Part 37):2022 (Spectrophotometric Method)	
Note							
1. This Certificate refers only to the particular sample(s) submitted for testing based on the sample sent to the laboratory.							
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.							
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.							
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.							
5.BDL:Below Detection Limit.							
6.N.A: Not Applicable.							
-----End of Report-----							
Prepared By				Authorized Signatory			
(Shailendra Kumar)				District Level Water Analysis Laboratory			
Lab Technician				Bahraich - U.P. IN			
				(Shamshad Ahmad)			
				Technical Manager			
Laboratory Contact details-Email-eebahraichlab@gmail.com, Mob-8382064686							



Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), BAHRAICH
Plot No. 2763, Jal Nigam Colony, Jail Road Bahraich, Uttar Pradesh-271801

Rept No. 41 Chemical Test /DWLT2025156 Date of 12.08.2025 S.No. 41 Page No. 1/1

Customer Details: BARROW'S BLUE BELL SCHOOL

Office Name and Address of the Customer: Barrow's Blue Bell School Block Chittaura Nagraur Bahraich.

Ref Letter No & Date

Basic details of sample

District	Bahraich	Block	
Gram Panchayat		Village	
Habitation		Location	Block Chittaura Nagraur Bahraich.
Water Source	Tap water	Sample No.	1
Quantity of Sample	1000 ml	Date of Collection	11.08.2025
Receiving Date	11.08.2025	Sample Collector	
Sample Depositer			
Analysis Start Date	11.08.2025	Analysis Completion Date	12.08.2025

Environmental Condition

Temperature	25±2°C	Relative Humidity	Upto 70%
-------------	--------	-------------------	----------

Technical Data of Analysis

S.No.		Units	Observed Value	Specified Values		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Total coliform	No. Per 100 ml	0	Nil	Nil	Membrane filtration Technique
2	E. coli	No. Per 100 ml	0	Nil	Nil	Membrane filtration Technique

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepared By

(Shailendra Kumar)
Lab Technician

Authorized Signatory

Technical Manager
District Level Water Analysis Laboratory
(Shamshad Ahmad)
Technical Manager

Laboratory Contact details-Email-eebahraichlab@gmail.com, Mob-8382064686

Drinking Water Sanitary Inspection form for Piped Water Supply

I. Type of facility: Piped water supply

1. General Information:

- a) District: Bahraich
- b) Location: Bareilly Blue Belle School Ganga Road Nagaura Bahraich
- c) Date of Visit: 12/01/2015

4. Water samples taken? Yes Sample Nos. 1 E.coli/ 100 ml. 0

II. Specific diagnosis information for assessment:

(Please indicate at which sample sites the risk was identified)

Survey Checklist			
S.N	Survey Points	Yes	No
1	Do any stand posts leak?		✓
2	Does surface water collect around any Tap Water?		✓
3	Is the area uphill of any Tap Water eroded?		✓
4	Are pipes exposed close to any Tap Water?		✓
5	Is Human excreta on the ground within 10m of any Tap Water?		✓
6	Is there a sewer within 30m of any Tap Water?		✓
7	Has there been a disconnuity in the last 10.days at any stand post?		✓
8	Are there signs of leaks in the main pipes?		✓
9	Do the community report any pipe breaks in the last week?		✓
10	Is the main pipe exposed anywhere in the vicinity?	✓	
Total Score of Risk		<u>1</u>	

Risk Score Card			
Risk Hazard	Risk Score	Risk Category Identified	Remark
Low	0-3	<u>1</u>	
Medium	3-5		
High	6-8		
Very High	9-10		


III. Results and recommendation: Drinking water is safe & there is no contamination around the water source.

The following important points of risk were noted: (list nos. 1-10)

On the above survey observation School is found under Low Hazards (0-3) category.

Signature of surveyor: Shamsher (Technical Manager)

Comments: Source is safe for drinking


Technical Manager
 District Level Water Analysis Laboratory
 Bahraich - UP IN